

## City of Bozeman Backflow Testing & Technician Requirements

- **Technicians:**
  - Shall have a current [American Backflow Prevention Association](#) Certified Tester certificate on file with the City
  - Shall have a current test kit/gauge calibration certificate on file with the City.
  - Shall use the provided [test form](#) that is found at [bozemanbackflow.com](http://bozemanbackflow.com) when submitting a test to the City
  - Technicians & other company staff who are handling tests are to have read and know our web test procedures, found on our webpage.
  - **Re-test/annual test results must be submitted through the web test entry portal within 30 days of the test.**
  
- **Tests must include the following minimum information (in addition to test results):**
  - Test **must be a passing test**. If test fails, assembly must be repaired/replaced and re-tested. No test is to be submitted until backflow assembly passes.
  - 8-digit **meter serial number** of domestic or irrigation water meter at location of assembly being tested.
  - **Address** of building where assembly was tested
  - **Assembly information**: make, model, size, serial number
  - **Date** of test
  - Technician **ABPA certification** number
  - Test **gauge/kit serial number**
  - **Static pressure** of service on which assembly was tested
  - **Type (hazard)** of service on which assembly was tested (fire, domestic, irrigation)
  - Description of **location** in building where assembly is located



*Tim Tusken*, CCCS, BPAT, WDC-1A, Water Operator Class II  
Cross-Connection Control Specialist/Backflow & FOG Prevention  
City of Bozeman Utility Operations

[ttusken@bozeman.net](mailto:ttusken@bozeman.net) – 406-582-3221 -- [bozemanbackflow.com](http://bozemanbackflow.com)