



NOTES:

1. THIS INSTALLATION ~~MAY~~ **SHALL** BE USED IF DEPTH OF COVER AT STUB END WILL EXCEED 6.5' WITH STANDARD INSTALLATION (PER STANDARD DRAWING 02730-2) **UNLESS AN ALTERNATIVE IS APPROVED BY THE CITY ENGINEER.**
2. MIN. DEPTH OF COVER SHALL BE 5' AT END OF SERVICE STUB. ENGINEER SHALL BE RESPONSIBLE FOR DETERMINING REQUIRED ELEVATION OF STUB.
3. DUCTILE IRON FITTINGS SHALL BE HARCO GASKET X GASKET OR APPROVED EQUAL.

CITY OF BOZEMAN STANDARD DRAWING	SCALE: NONE	DEEP SANITARY SEWER SERVICE LINE	NO. 02730-3 MAY 2021
-------------------------------------	----------------	-------------------------------------	-------------------------