

VACATION RENTAL INSPECTION FORM

NAME _____ DATE: November 30, 2017

ADDRESS: _____ TIME: 10:30 AM

1. Address - plainly visible from street, 4 inch minimum? yes no _____
2. Smoke Detector: Are smoke detectors provided in each sleeping room, and in areas giving access to sleeping rooms? One on each level including basements? yes no _____
3. Are portable fire extinguishers provided? yes no _____
4. Are emergency egress windows provided from each sleeping room? Minimum dimensions are: 5.7 square feet clear opening, height 24 inches, width 20 inches. Maximum height from the floor, 44 inches? yes no _____
5. Are all exit doors and egress windows operable? yes no _____
6. Are all exit paths unobstructed? yes no _____
7. Is the garage separated from the dwelling unit and attic area by a minimum of ½ gypsum wallboard on the garage side and a 20 minute door? yes no _____
8. Flammable liquids stored in approved quantities to be kept in tight containers stored in approved cabinets. ? yes no _____
9. City Business License? yes no _____
10. Other conditions affecting safety of the public: APPROVED

Inspector(s): Jack Coburn (406) 582-2386 

Manager _____

APPROVED