

City of Bozeman Local Limits

(Ordinance 1923 40.03.115)

Pollutant	Maximum Daily Limit (mg/L)	Average Monthly Limit (mg/L)
Arsenic	0.261	0.068
Cadmium	0.182	0.018
Chromium	4.832	4.83
Copper	1.75	0.910
Lead	0.634	0.317
Mercury	0.002	0.002
Molybdenum	0.283	0.283
Nickel	1.943	0.977
Selenium	0.464	0.110
Silver	0.722	5.29
Zinc	4.14	4.14